

NOMOR 5 TAHUN 2012
TENTANG
PERUBAHAN ATAS PERATURAN DAERAH
PROVINSI JAWA TENGAH NOMOR 10 TAHUN 2004
TENTANG BAKU MUTU AIR LIMBAH

BAKU MUTU AIR LIMBAH UNTUK KEGIATAN RUMAH SAKIT

NO	PARAMETER	SATUAN	KADAR MAKSIMUM
I.	FISIKA		
1.	Suhu	°C	30
2.	TSS	mg/L	30
II.	KIMIA		
1.	pH	-	6,0 – 9,0
2.	BOD ₅	mg/L	30
3.	COD	mg/L	80
4.	NH ₃ -N Bebas	mg/L	0,1
5.	Phosphat (PO ₄ -P)	mg/L	2
III.	MIKROBIOLOGI		
1.	Kuman Golongan Coli	MPN/100 mL	5.000
IV.	RADIOAKTIVITAS		
1.	³² P	Bq/L	7 x 10 ²
2.	³⁵ S	Bq/L	2 x 10 ³
3.	⁴⁵ Ca	Bq/L	3 x 10 ²
4.	⁵¹ Cr	Bq/L	7 x 10 ⁴
5.	⁶⁷ Ga	Bq/L	1 x 10 ³
6.	⁸⁵ Sr	Bq/L	4 x 10 ³
7.	⁹⁹ Mo	Bq/L	7 x 10 ³
8.	¹¹³ Sn	Bq/L	3 x 10 ³
9.	¹²⁵ I	Bq/L	1 x 10 ⁴
10.	¹³¹ I	Bq/L	7 x 10 ⁴
11.	¹⁹² Ir	Bq/L	1 x 10 ⁴
12.	²⁰¹ Ti	Bq/L	1 x 10 ⁵

GUBERNUR JAWA TENGAH,

ttd

BIBIT WALUYO